



Intertek LSS Scheme Tick Mark Certificate

15LHK0532-09

This is to certify that:

The mentioned product
complies with the mentioned
test requirement

ZFP Range of Addressable Fire Alarm Panels, XP95 / Discovery Protocol

Is in conformity with the following standard(s):

EN54-2:1997+A1:2006, EN54-4:1997+A1:2002+A2:2006

Report Number(s):

103729070LHD-001, 101237162LHD-001, BMA 10096 dated 18.07.2013, 104568404, 105174926

Computationics Limited (Trading as C-TEC)

Challenge Way, Martland Park, Wigan, WN5 0LD, UK

and is authorised to use the Intertek Tick Mark for the LSS Scheme on the
above mentioned product(s)

This certificate is valid until:

23rd July 2027

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

Limitations:	Certification Body: ITCL
See ANNEX No. 2	LSS Reference: LSS 0496
	Issued Date: 24 th July 2023

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



Certification Officer

S Yathunathan



Intertek LSS Scheme

Tick Mark Certificate

15LHK0532-09

The mentioned product complies with the mentioned test requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 1

Brand and Type/Model	Description	Factory Code
C-Tec ZFP-1	ZFP-1 1 Loop Fire Alarm Control Panel	CTECUK.01
C-Tec ZFP-2	ZFP-2 2 Loop Fire Alarm Control Panel	CTECUK.01
C-Tec ZFP-4	ZFP-4 4 Loop Fire Alarm Control Panel	CTECUK.01

ANNEX No. 2

The optional features of the specifications that are included in the product and test report:

- 7.8 Output to fire alarm devices
- 7.11 Delays to outputs
- 7.12 Dependencies on more than one alarm signal
- 8.3 Fault signals from points
- 9.5 Disabling of addressable points
- 10 Test Condition

Conditions of use:

Suitable for indoor applications

Products compliant with EN54-2:1997+A1:2006:

ZFP-Series ZFP-x Loop Fire Alarm Control Panel

Variant	Description
ZFP-1	ZFP-1 Loop Fire Alarm Control Panel
ZFP-2	ZFP-2 Loop Fire Alarm Control Panel
ZFP-4	ZFP-4 Loop Fire Alarm Control Panel

Comprising:

ZFP-Series	Fire Alarm Control Panel
BF562-5	Power Supply



Intertek LSS Scheme

Tick Mark Certificate

15LHK0532-09

The mentioned product complies with the mentioned test requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

ANNEX No. 2

Approved Accessories:

Z48	40-Zone Indicator Module
Z02LOOP/X	Loop Expansion Board
Z11	4 Relay PCB
Z12	8 Relay PCB
Z13	8-I/O PCB
Z14	16-I/O PCB

Products compliant with EN54-4:1997+A1:2002+A2:2006:

Power Supply

Variant	Description
BF562-5	Power Supply

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.