



Declaration of Performance – DOP0000043 EU **According to Construction Products Regulation EU N° 305/2011**

1. Unique Product identification code:

BF430A/CX/SR, BF430A/CX/DR, BF433A/CX/SR, BF433A/CX/DR

2. Type number allowing identification of the construction product as required pursuant to Article 11(4):

Hi-Output 103dB(A) Type A Wall Sounder, shallow base, red plastic housing (BF430A/CX/SR)
Hi-Output 103dB(A) Type B Wall Sounder, deep base, red plastic housing (BF430A/CX/DR)
Hi-Output W-2.4-8.2 Type A Wall VAD c/w 103dB(A) Sounder, shallow base, red plastic housing (BF433A/CX/SR)
Hi-Output W-2.4-8.2 Type B Wall VAD c/w 103dB(A) Sounder, deep base, red plastic housing (BF433A/CX/DR)

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Models BF430A/CX/SR, BF430A/CX/DR, BF433A/CX/SR, BF433A/CX/DR:

Sounders to EN 54-3: 2001 for use in Fire detection and fire alarm systems in buildings

Models BF430A/CX/SR, BF430A/CX/DR, BF433A/CX/SR, BF433A/CX/DR:

Short-circuit isolators to EN 54-17: 2005 for use in Fire detection and fire alarm systems in buildings

Models BF433A/CX/SR, BF433A/CX/DR:

Visual alarm devices to EN 54-23: 2010 for use in Fire detection and fire alarm systems in buildings

4. Name, registered trade name or registered trademark and contact address of the manufacturer as required pursuant to Article 11(5):

Computationics Limited (C-TEC)
Challenge Way, Martland Park, Wigan, WN5 0LD. United Kingdom
Tel: 01942 322744. Fax: 01942 829867

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not Applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. Notified body, in the case of the declaration of performance concerning a construction product covered by a harmonized standard:

Loss Prevention Certification Board (LPCB) (Notified Body Number 2831)
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road,
Glasnevin, Dublin, D11 KXN4
Ireland

has performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:

BF430A/CX/SR: 2831-CPR-F0942
BF430A/CX/DR: 2831-CPR-F0943
BF433A/CX/SR: 2831-CPR-F0944
BF433A/CX/DR: 2831-CPR-F0945



8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7

9(a). Declared performance applicable to models BF430A/CX/SR, BF430A/CX/DR, BF433A/CX/SR, BF433A/CX/DR:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the hEN mentioned in the following table.

Harmonised Technical Specification		EN 54-3: 2001 + A1: 2002 + A2: 2006
Essential Characteristics	Performance	Clause
Performance parameters under fire condition - Sound level - Frequency and sound patterns - Reproducibility - Operational performance - Attention drawing signal and message broadcast sequences - Synchronisation (option with requirements) - Broadcast message performance - Attention-drawing signal silence message sequence timing - Message synchronisation testing option with requirements	Pass Pass Pass Pass NPD NPD NPD NPD NPD	4.2 4.3 5.2 5.3 C.3.1 C.3.2 C.5.1 C.5.2 C.5.3
Operational reliability - Durability - Construction - Marking and data - Durability - General testing	Pass Pass Pass Pass NPD	4.4 4.5 4.6 5.4 C4
Durability of operational reliability Temperature resistance: - Dry heat (operational) - Dry heat (endurance) - Cold (operational) - Damp heat, cyclic (operational) - Damp heat, steady state (endurance) Humidity resistance: - Damp heat, cyclic (operational) - Damp heat, steady state (endurance) - Damp heat, cyclic (endurance) Corrosion resistance: - Sulfur dioxide (SO₂) corrosion (endurance) Shock and vibration resistance: - Shock (operational) - Impact (operational) - Vibration, sinusoidal (operational) - Vibration, sinusoidal (endurance) Electrical stability: - Electromagnetic compatibility (EMC), immunity (operational) Resistance to ingress: - Enclosure protection	Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass	5.5 5.6 5.7 5.8 5.9 5.8 5.9 5.10 5.11 5.12 5.13 5.14 5.15 5.16 5.17
Meets the requirements of EN 54-3 for the following (operating voltage range 17-28 VDC): Tone 1 - Primary - Evacuate, 572Hz for 0.5s, 720Hz for 0.5s - Alternating, 962Hz for 0.25s, 572Hz for 0.25s - Dutch slow sweep, 500Hz to 1200Hz for 3.5s on, 0.5s off		



9(b). Declared performance applicable to models BF430A/CX/SR, BF430A/CX/DR, BF433A/CX/SR, BF433A/CX/DR:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the hEN mentioned in the following table.

Harmonised Technical Specification		EN 54-17: 2005
Essential Characteristics	Performance	Clause
Performance under fire conditions - Reproducibility ⁽¹⁾	Pass	5.2
Operational reliability - General requirements	Pass	4
Durability of operational reliability (temperature resistance) - Dry heat (operational)	Pass	5.4
- Cold (operational)	Pass	5.5
Durability of operational reliability (vibration resistance) - Shock (operational)	Pass	5.9
- Impact (operational)	Pass	5.10
- Vibration, sinusoidal (operational)	Pass	5.11
- Vibration, sinusoidal (endurance)	Pass	5.12
Durability of operational reliability (humidity resistance) - Damp heat, cyclic (operational)	Pass	5.6
- Damp heat, steady state (operational)	Pass	5.7
Durability of operational reliability (corrosion resistance) - Sulphur dioxide (SO ₂) corrosion (endurance)	Pass	5.8
Durability of operational reliability (electrical stability) - Variation in supply voltage	Pass	5.3
- Electromagnetic Compatibility (EMC), Immunity tests (operational)	Pass	5.13
⁽¹⁾ This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices.		



9(c). Declared performance applicable to models BF433A/CX/SR, BF433A/CX/DR:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the hEN mentioned in the following table.

Harmonised Technical Specification		EN 54-23: 2010
Essential Characteristics	Performance	Clause
Operational reliability - Duration of operation - Provision for external conductors - Flammability of materials - Enclosure protection - Access - Manufacturer's adjustments - On-site adjustment of behaviour - Requirements for software controlled devices	Pass Pass Pass Pass Pass Pass Pass Pass	4.2.1 4.2.2 4.2.3 4.2.4 4.2.5 4.2.6 4.2.7 4.2.8
Performance parameters under fire condition - Coverage volume - Variation of light output - Minimum and maximum light intensity - Light colour - Light temporal pattern and frequency of flashing - Marking and data - Synchronisation (option with requirements)	Pass Pass Pass White Pass/0.5Hz Pass Pass	4.3.1 4.3.2 4.3.3 4.3.4 4.3.5 4.3.6 4.3.7
Durability Temperature resistance: - Dry heat (operational) - Dry heat (endurance) - Cold (operational) Humidity resistance: - Damp heat, cyclic (operational) - Damp heat, steady state (endurance) - Damp heat, cyclic (endurance) Shock and vibration resistance: - Shock (operational) - Impact (operational) - Vibration (operational) - Vibration (endurance) Corrosion resistance: - SO2 corrosion (endurance) Electrical stability: - EMC, immunity (operational)	Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass Pass	4.4.1.1 4.4.1.2 4.4.1.3 4.4.2.1 4.4.2.2 4.4.2.3 4.4.3.1 4.4.3.2 4.4.3.3 4.4.3.4 4.4.4 4.4.5
Meets the requirements of EN 54-23 for the following: - Category W-2.4-8.2 - Flash rate 0.5Hz - Synchronisation - Operating voltage range 21-28 VDC		

10. Empowered Signatory of Company

Name: Daniel Foster
Position: Head of Science
Signature: 
Date: 1 March 2022