

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F4090

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

EP203 Conventional Three Zone "Class A" Extinguisher Control Panel

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Computationics Limited (Trading as C-Tec)
Challenge Way
Martland Park
Wigan
WN5 OLD
United Kingdom

Computationics Limited (Trading as C-Tec)
Challenge Way
Martland Park
Wigan
WN5 OLD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and Indicating Equipment

EN 54-4:1997 + A1:2002 + A2:2006 - Power Supply Equipment

EN 12094-1:2003 - Components for Gas Extinguishing Systems - Requirements and Test Methods for Electrical Automatic Control and Delay Devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 23 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Signature here

, Certification Engineer

Date of First Issue: 23 October 2019

Date of Issue: 23 October 2019

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4090**EP203 Conventional Three Zone "Class A" Extinguisher Control Panel****Variants:**

EP203/DE Conventional three zone "class A" extinguisher control panel German Language Variant
EP203/CON Conventional three zone "class A" extinguisher control panel branded under Context Plus

Incorporating the following units:

SPF0000203 Main extinguisher control
SPF0000212 External relay interface
SPF0003613 Power supply unit
SPF0000214 EP214 Terminal

Incorporating modular units:

EP210S Remote Status Unit "Surface Mount" optional (See Note 1)
EP211 Economy Status Unit optional (See Note 1)

Certified with the following options with the requirements from EN 12094-1:2003

- 4.17 Delay of extinguisher signal
- 4.18 Signal representing the flow of extinguishing agent
- 4.19 Monitoring of the status of components
- 4.20 Emergency hold device
- 4.21 Control of flooding time
- 4.23 Manual only mode
- 4.26 Triggering of equipment outside the system
- 4.27 Emergency abort device
- 4.30 Activation of alarm devices with different signals

Certified with the following options with requirements from EN 54-2:1997

- 7.8 Output to fire alarm device(s)
- 7.11 Delays to the auctioning of outputs fire alarm devices and fire routing equipment
- 7.13 Alarm counter
- 10 Test condition

Signature here

, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 23 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4090

Certified with the following options with requirements from EN 54-2:1997

- 7.8 Output to fire alarm device(s)
- 7.11 Delays to the auctioning of outputs fire alarm devices and fire routing equipment
- 7.13 Alarm counter
- 10 Test condition

Notes:

- 3) Optional Remote Status Unit part No. EP210S & Economy Status Unit part No. EP211 are not certified as meeting the requirements of the standards specified.
- 4) Meets the requirements of EN12094-3:2003, Class A – i.e. operational temperature range of -5°C to +40°C.

Signature here

, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 23 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.