

## Certificate of Product Approval

Certificate Number: 176k

Issue: 02

### Compuionics Limited t/a C-TEC

Challenge Way  
Martland Park  
Wigan  
Lancashire  
WN5 0LD  
United Kingdom



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Smoke Detectors

CA416

HP416

(refer to Appendix for details)

#### Standards

EN 54-7:2000 + A1:2002 + A2:2006

EN 54-17:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

08 June 2020

Date of Issue

15 June 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 176k Compuionics Limited t/a C-TEC

Issue: 02

Certified Product	Description	LPCB Ref.No.
CA416	CAST Optical Smoke Detector with Short Circuit Isolator (CA408, CA431A/W, CA456A/W, CA460A/W) Note: 1. Meets the requirements of EN 54-7 at high and medium sensitivity settings.	176k/01
HP416	HP Optical Smoke Detector with Short Circuit Isolator (HP408) Note: 1. Meets the requirements of EN 54-7 at high and medium sensitivity settings.	176k/01

### Bases

CA408	CAST Detector Standard Base
CA431A/W	CAST Base Sounder with Short Circuit Isolator
CA456A/W	CAST Base Sounder VAD with Short Circuit Isolator
CA460A/W	CAST Base VAD with Short Circuit Isolator
HP408	HP Standard Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan  
Verifier

08 June 2020  
Date of Issue

15 June 2018  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


