



## Declaration of Performance – DOP0000042 EU According to Construction Products Regulation EU N° 305/2011

### 1. Unique Product identification code:

BF450A/CX/SW, BF450A/CX/SR, BF451A/CX/SW, BF451A/CX/SR, BF458A/CX/SW, BF458A/CX/SR

### 2. Type number allowing identification of the construction product as required pursuant to Article 11(4):

Compact 91dB(A) Ceiling / Wall Sounder, white plastic housing (BF450A/CX/SW)  
Compact 91dB(A) Ceiling / Wall Sounder, red plastic housing (BF450A/CX/SR)  
Compact C-3-8 / W-3-3.1 VAD c/w 91dB(A) sounder, white plastic housing (BF451A/CX/SW)  
Compact C-3-8 / W-3-3.1 VAD c/w 91dB(A) sounder, red plastic housing (BF451A/CX/SR)  
Compact C-3-8 / W-3-3.1 VAD only, white plastic housing (BF458A/CX/SW)  
Compact C-3-8 / W-3-3.1 VAD only, red plastic housing (BF458A/CX/SR)

### 3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

**Models BF450A/CX/SW, BF450A/CX/SR, BF451A/CX/SW, BF451A/CX/SR:**  
Sounders to EN 54-3: 2001 for use in Fire detection and fire alarm systems in buildings

**Models BF450A/CX/SW, BF450A/CX/SR, BF451A/CX/SW, BF451A/CX/SR, BF458A/CX/SW, BF458A/CX/SR:**  
Short-circuit isolators to EN 54-17: 2005 for use in Fire detection and fire alarm systems in buildings

**Models BF451A/CX/SW, BF451A/CX/SR, BF458A/CX/SW, BF458A/CX/SR:**  
Visual alarm devices to EN 54-23: 2010 for use in Fire detection and fire alarm systems in buildings

### 4. Name, registered trade name or registered trademark and contact address of the manufacturer as required pursuant to Article 11(5):

Computationics Limited (C-TEC)  
Challenge Way, Martland Park, Wigan, WN5 0LD. United Kingdom  
Tel: 01942 322744. Fax: 01942 829867

### 5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not Applicable

### 6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

### 7. Notified body, in the case of the declaration of performance concerning a construction product covered by a harmonized standard:

Intertek Deutschland GmbH (Notified Body Number 0905)  
Stangenstraße 1, 70771 Leinfelden-Echterdingen  
Germany

has performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:

0905-CPR-00446





**9(b). Declared performance applicable to models BF450A/CX/SW, BF450A/CX/SR, BF451A/CX/SW, BF451A/CX/SR, BF458A/CX/SW, BF458A/CX/SR:**

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the hEN mentioned in the following table.

Harmonised Technical Specification		EN 54-17: 2005
Essential Characteristics	Performance	Clause
<b>Performance under fire conditions</b> - Reproducibility <sup>(1)</sup>	Pass	5.2
<b>Operational reliability</b> - General requirements	Pass	4
<b>Durability of operational reliability (temperature resistance)</b> - Dry heat (operational) - Cold (operational)	Pass	5.4
	Pass	5.5
<b>Durability of operational reliability (vibration resistance)</b> - Shock (operational) - Impact (operational) - Vibration, sinusoidal (operational) - Vibration, sinusoidal (endurance)	Pass	5.9
	Pass	5.10
	Pass	5.11
	Pass	5.12
<b>Durability of operational reliability (humidity resistance)</b> - Damp heat, cyclic (operational) - Damp heat, steady state (operational)	Pass	5.6
	Pass	5.7
<b>Durability of operational reliability (corrosion resistance)</b> - Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	Pass	5.8
<b>Durability of operational reliability (electrical stability)</b> - Variation in supply voltage - Electromagnetic Compatibility (EMC), Immunity tests (operational)	Pass	5.3
	Pass	5.13

<sup>(1)</sup> This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices.




**9(c). Declared performance applicable to models BF451A/CX/SW, BF451A/CX/SR, BF458A/CX/SW, BF458A/CX/SR:**

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. above have been determined as described in the hEN mentioned in the following table.

Harmonised Technical Specification		EN 54-23: 2010
Essential Characteristics	Performance	Clause
<b>Operational reliability</b> <ul style="list-style-type: none"> <li>- Duration of operation</li> <li>- Provision for external conductors</li> <li>- Flammability of materials</li> <li>- Enclosure protection</li> <li>- Access</li> <li>- Manufacturer's adjustments</li> <li>- On-site adjustment of behaviour</li> <li>- Requirements for software controlled devices</li> </ul>	Pass Pass Pass Pass Pass Pass Pass Pass	4.2.1 4.2.2 4.2.3 4.2.4 4.2.5 4.2.6 4.2.7 4.2.8
<b>Performance parameters under fire condition</b> <ul style="list-style-type: none"> <li>- Coverage volume</li> <li>- Variation of light output</li> <li>- Minimum and maximum light intensity</li> <li>- Light colour</li> <li>- Light temporal pattern and frequency of flashing</li> <li>- Marking and data</li> <li>- Synchronisation (option with requirements)</li> </ul>	Pass Pass Pass White Pass/0.5Hz Pass Pass	4.3.1 4.3.2 4.3.3 4.3.4 4.3.5 4.3.6 4.3.7
<b>Durability</b> <b>Temperature resistance:</b> <ul style="list-style-type: none"> <li>- Dry heat (operational)</li> <li>- Dry heat (endurance)</li> <li>- Cold (operational)</li> </ul> <b>Humidity resistance:</b> <ul style="list-style-type: none"> <li>- Damp heat, cyclic (operational)</li> <li>- Damp heat, steady state (endurance)</li> <li>- Damp heat, cyclic (endurance)</li> </ul> <b>Shock and vibration resistance:</b> <ul style="list-style-type: none"> <li>- Shock (operational)</li> <li>- Impact (operational)</li> <li>- Vibration (operational)</li> <li>- Vibration (endurance)</li> </ul> <b>Corrosion resistance:</b> <ul style="list-style-type: none"> <li>- SO2 corrosion (endurance)</li> </ul> <b>Electrical stability:</b> <ul style="list-style-type: none"> <li>- EMC, immunity (operational)</li> </ul>	Pass NPD Pass Pass Pass NPD Pass Pass Pass Pass Pass Pass	4.4.1.1 4.4.1.2 4.4.1.3 4.4.2.1 4.4.2.2 4.4.2.3 4.4.3.1 4.4.3.2 4.4.3.3 4.4.3.4 4.4.4 4.4.5
Meets the requirements of EN 54-23 for the following: <ul style="list-style-type: none"> <li>- Category C-3-8 or W-3-3.1</li> <li>- Flash rate 0.5Hz</li> <li>- Synchronisation</li> <li>- Operating voltage range 21-28 VDC</li> </ul>		

**10. Empowered Signatory of Company**

Name: Daniel Foster  
 Position: Head of Science  
 Signature:   
 Date: 15th August 2022