BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F4508

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

ZFP1/CA ZFP 1 Loop Analogue Addressable Control and Indication Equipment, 5A PSU, Standard Cabinet
(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

Computionics Limited (Trading as C-Tec)
Challenge way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

and produced in the manufacturing plant(s):

Computionics Limited (Trading as C-Tec)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 09 March 2021 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

E. Mattie-Suleiman, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 9 March 2021
Date of Issue: 9 March 2021
Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

© BRE Global Assurance (Ireland) Limited, 2021

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4508

ZFP1/CA ZFP 1 Loop Analogue Addressable Control and Indication Equipment, 5A PSU, Standard Cabinet

Incorporating the following modular units:

RPF0000051	Main display PCB
RPF0999308	Loop 1 – 2 PCB
RPF0000060	Credit Card processor board
RPF0361020	5 Amp PSU module

Optional Modules:

RPF0000028	Z11 - 4-way relay PCB
RPF0000029	Z13 - 8 way I/O PCB

Certified with the following options with requirements from EN 54-2:

7.8	Output to fire alarm devices
7.11	Delays to outputs
7.12.1	Dependencies on more than one alarm signal – Type A
7.12.2	Dependencies on more than one alarm signal – Type B
7.13	Alarm counter
8.3	Fault signal from points
9.5	Disablement of each addressable point
10	Test Condition

Notes:
1. This product approval does not constitute compliance with the fire detection and alarm systems requirements of EN54-13.

E. Mattie-Suleiman, Certification Engineer,
On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 9 March 2021
Date of issue: 9 March 2021
Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

© BRE Global Assurance (Ireland) Limited, 2021