

BRE Global Ireland

Notified Body No. 2831
BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F0386

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

CFP702-2, CFP704-2, CFP708-2

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Computationics Limited (Trading as C-Tec)
Challenge Way
Martland Park
Wigan, Lancashire
WN5 0LD
United Kingdom

Computationics Limited (Trading as C-Tec)
Challenge Way
Martland Park
Wigan, Lancashire
WN5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 – Control and Indicating Equipment
EN 54-4:1997 + A1:2002 + A2:2006 – Power Supply Equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 23 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Certification Engineer, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of Issue: 23 October 2019

Issue number 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.

BRE Global Ireland**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0386**CFP702-2, CFP704-2, CFP708-2**

The details and conditions of use for the following products, placed on the market by Computationics Limited (Trading as C-Tec) are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (where applicable):

CFP702-2

Alarmsense two zone conventional control and indicating equipment

Incorporating the following units:

SPF0702480 Switch mode power supply unit board

SPF0724851 2 Zone main control board

Certified with the following options with requirements from EN 54-2:1997

7.8 Output to fire alarm device(s)

7.11 Delays to outputs

10 Test condition

CFP704-2

Alarmsense four zone conventional control and indicating equipment

Incorporating the following units:

SPF0702480 Switch mode power supply unit board

SPF0724853 4 Zone main control board

Certified with the following options with requirements from EN 54-2:1997

7.8 Output to fire alarm device(s)

7.11 Delays to outputs

10 Test condition

CFP708-2

Alarmsense eight zone conventional control and indicating equipment

Incorporating the following units:

SPF0702480 Switch mode power supply unit board

SPF0724855 8 Zone main control board



Certification Engineer, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 23 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.



BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland

T: +353 (0) 18824344

E: enquiries@breglobalireland.ie

www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F0386

Certified with the following options with requirements from EN 54-2:1997

7.8 Output to fire alarm device(s)

7.11 Delays to outputs

10 Test condition

Certification Engineer, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 23 October 2019

Issue number: 01

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie.