

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F4311

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

XFP501/H 1 Loop, 32 Zone Analogue Addressable Control and Indicating Equipment using Hochiki Protocol, Metal Housing

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

Computationics (trading as CTEC) Ltd
Challenge Way
Martland Park
Wigan, Lancashire
WN5 0LD
United Kingdom

Computationics (trading as CTEC) Ltd
Challenge Way
Martland Park
Wigan, Lancashire
WN5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2: 1997 + A1: 2006 - Control and Indicating Equipment
EN 54-4: 1997 + A1: 2002 + A2: 2006 - Power Supply Equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 23 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

P. Halligan

P Halligan, Certification Engineer

Date of First Issue: 23 October 2019

Date of Issue: 26 May 2021

On behalf of BRE Global Assurance (Ireland) Limited

Issue number 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F4311

XFP501/H 1 Loop, 32 Zone Analogue Addressable Control and Indicating Equipment using Hochiki Protocol, Metal Housing

Incorporating the following units:

SPF0501435 XFP Hochiki 1 loop, Mainboard
SPF0501199 Display board (Keypad display)
SPF0501021 Switch mode power supply board

Optional language variants;

XFP501/H/NL Dutch language variant

Certified with the following options with requirements from EN54-2: 1997

7.8 Output to fire alarm device(s)
7.11 Delays to the actioning of outputs fire alarm devices and fire routing equipment
7.12.1 Dependencies on more than one alarm signal - Type A
7.12.2 Dependencies on more than one alarm signal - Type B
7.12.3 Dependencies on more than one alarm signal - Type C
7.13 Alarm counter
8.3 Fault signals from points
9.5 Disablement of each address point
10 Test condition

Notes:

1. Scope of approval does not include the operation of the network functionality.
2. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.

P. Halligan

P Halligan, Certification Engineer,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 23 October 2019

Date of issue: 26 May 2021

Issue number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie