

BRE Global**UK Approved Body No. 0832**

BRE Global Limited
 Bucknalls Lane, Garston, Watford,
 Hertfordshire, UK, WD25 9XX
 Telephone: +44 (0) 333 321 8811
 Fax: +44 (0)1923 664603
 Email: enquiries@breglobal.com
 Web: www.breglobal.com

Certificate of UKCA approval constancy of performance

0832-UKCA-CPR-F1054

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

ZFP1/CA 1 Loop Analogue Addressable Control and Indication Equipment, 5A PSU, Standard Cabinet

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 04 July 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1054

ZFP1/CA 1 Loop Analogue Addressable Control and Indication Equipment, 5A PSU, Standard Cabinet

Incorporating the following modular units:

RPF0000051 Main display PCB
RPF0999308 Loop 1 – 2 PCB
RPF0000060 Credit Card processor board
RPF0361020 5 Amp PSU module

Optional Modules:

RPF0000028 Z11 - 4-way relay PCB
RPF0000029 Z13 - 8 way I/O PCB

Certified with the following options with requirements from EN 54-2:

- 7.8 Output to fire alarm devices
- 7.11 Delays to outputs
- 7.12.1 Dependencies on more than one alarm signal – Type A
- 7.12.2 Dependencies on more than one alarm signal – Type B
- 7.13 Alarm counter
- 8.3 Fault signal from points
- 9.5 Disablement of each addressable point
- 10 Test Condition

Notes:

1. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global**UK Approved Body No. 0832**

BRE Global Limited
 Bucknalls Lane, Garston, Watford,
 Hertfordshire, UK, WD25 9XX
 Telephone: +44 (0) 333 321 8811
 Fax: +44 (0)1923 664603
 Email: enquiries@breglobal.com
 Web: www.breglobal.com

Certificate of UKCA approval constancy of performance

0832-UKCA-CPR-F1055

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

ZFP2/CA 2 Loop Analogue Addressable Control and Indication Equipment, 5A PSU, Standard Cabinet

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 04 July 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F1055

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

ZFP2/CA 2 Loop Analogue Addressable Control and Indication Equipment, 5A PSU, Standard Cabinet

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 04 July 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

BRE Global**UK Approved Body No. 0832**

BRE Global Limited
 Bucknalls Lane, Garston, Watford,
 Hertfordshire, UK, WD25 9XX
 Telephone: +44 (0) 333 321 8811
 Fax: +44 (0)1923 664603
 Email: enquiries@breglobal.com
 Web: www.breglobal.com

Certificate of UKCA approval constancy of performance

0832-UKCA-CPR-F1056

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2019 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

ZFP4/CA 4 Loop Analogue Addressable Control and Indicating Equipment, 5A PSU, Standard Cabinet

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 04 July 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1056

ZFP4/CA 4 Loop Analogue Addressable Control and Indicating Equipment, 5A PSU, Standard Cabinet

Incorporating the following modular units:

RPF0000051 Main display PCB
RPF0999308 Loop 1 – 2 PCB
RPF0999307 Loop 3 – 4 expansion PCB
RPF0000060 Credit Card processor board
RPF0361020 5 Amp PSU module

Optional Modules:

RPF0000028 Z11 - 4-way relay PCB
RPF0000029 Z13 - 8 way I/O PCB

Certified with the following options with requirements from EN 54-2:

- 7.8 Output to fire alarm devices
- 7.11 Delays to outputs
- 7.12.1 Dependencies on more than one alarm signal – Type A
- 7.12.2 Dependencies on more than one alarm signal – Type B
- 7.13 Alarm counter
- 8.3 Fault signal from points
- 9.5 Disablement of each addressable point
- 10 Test Condition

Notes:

1. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F1058

In compliance with the Construction Product Regulations 2019, UK Statutory Instruments 2019 No.465 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

ZFP2/40/CA 2 Loop Analogue Addressable Control and Indicating Equipment, 5A PSU, 40 Zone Indication, Standard Cabinet

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 04 July 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1058

ZFP2/40/CA 2 Loop Analogue Addressable Control and Indicating Equipment, 5A PSU, 40 Zone Indication, Standard Cabinet

Incorporating the following modular units:

RPF0000051	Main display PCB
RPF0999308	Loop 1 – 2 PCB
RPF0000025	Z47 - 40 LED Display
RPF0000060	Credit Card processor board
RPF0361020	5 Amp PSU module

Optional Modules:

RPF0000024	Z48 - 40 LED Display with 5 key switches
RPF0000028	Z11 - 4-way relay PCB
RPF0000029	Z13 - 8 way I/O PCB

Certified with the following options with requirements from EN 54-2:

7.8	Output to fire alarm devices
7.11	Delays to outputs
7.12.1	Dependencies on more than one alarm signal – Type A
7.12.2	Dependencies on more than one alarm signal – Type B
7.13	Alarm counter
8.3	Fault signal from points
9.5	Disabling of each addressable point
10	Test Condition

Notes:

1. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global**UK Approved Body No. 0832**

BRE Global Limited
 Bucknalls Lane, Garston, Watford,
 Hertfordshire, UK, WD25 9XX
 Telephone: +44 (0) 333 321 8811
 Fax: +44 (0)1923 664603
 Email: enquiries@breglobal.com
 Web: www.breglobal.com

Certificate of UKCA approval constancy of performance

0832-UKCA-CPR-F1059

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

ZFP4/40/CA 4 Loop Analogue Addressable Control and Indicating Equipment, 5A PSU, 40 Zone Indication, Standard Cabinet

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

Computationics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WD5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and indicating equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 04 July 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1059

ZFP4/40/CA 4 Loop Analogue Addressable Control and Indicating Equipment, 5A PSU, 40 Zone Indication, Standard Cabinet

Incorporating the following modular units:

RPF0000051 Main display PCB
RPF0999308 Loop 1 – 2 PCB
RPF0999307 Loop 3 – 4 expansion PCB
RPF0000025 Z47 - 40 LED Display
RPF0000060 Credit Card processor board
RPF0361020 5 Amp PSU module

Optional Modules:

RPF0000024 Z48 - 40 LED Display with 5 key switches
RPF0000028 Z11 – 4-way relay PCB
RPF0000029 Z13 - 8-way I/O PCB

Certified with the following options with requirements from EN 54-2:

7.8 Output to fire alarm devices
7.11 Delays to outputs
7.12.1 Dependencies on more than one alarm signal – Type A
7.12.2 Dependencies on more than one alarm signal – Type B
7.13 Alarm counter
8.3 Fault signal from points
9.5 Disablement of each addressable point
10 Test Condition

Notes:

1. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com