BRE Global

UK Approved Body No. 0832
BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance

0832-UKCA-CPR-F1043

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

XFP502/X 2 Loop, 32 Zone Analogue Addressable Control and Indicating Equipment using Apollo Protocol, Metal Housing

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of:

Computionics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WN5 0LD
United Kingdom

and produced in the manufacturing plant(s):

Computionics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan, Lancashire
WN5 0LD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2: 1997 + A1: 2006 - Control and Indicating Equipment
EN 54-4: 1997 + A1: 2002 + A2: 2006 - Power Supply Equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 04 July 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.

P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue:	04 July 2022
Issue Date:	04 July 2022
Issue Number:	01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

© BRE Global Limited, 2021

BRE Global

UK Approved Body No. 0832
BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1043

XFP502/X 2 Loop, 32 Zone Analogue Addressable Control and Indicating Equipment using Apollo Protocol, Metal Housing

Incorporating the following units:

SPF0501425	XFP Apollo 2 loop, Mainboard
SPF0501199	Display board (Keypad display)
SPF0501021	Switch mode power supply board

Certified with the following options with requirements from EN54-2: 1997

7.8	Output to fire alarm device(s)
7.11	Delays to the actioning of outputs fire alarm devices and fire routing equipment
7.12.1	Dependencies on more than one alarm signal - Type A
7.12.2	Dependencies on more than one alarm signal - Type B
7.12.3	Dependencies on more than one alarm signal - Type C
7.13	Alarm counter
8.3	Fault signals from points
9.5	Disablement of each address point
10	Test condition

Notes:

1. This product approval does not constitute compliance with the fire detection and alarm system requirements of EN54-13.

P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022
Issue Date: 04 July 2022
Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

© BRE Global Limited, 2021