

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of UKCA approval constancy of performance 0832-UKCA-CPR-F1111

In compliance with the Construction Product Regulations 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government. This certificate applies to the construction product.

EP203 Conventional Three Zone "Class A" Extinguisher Control Panel

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

Comptonics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan
WN5 OLD
United Kingdom

Comptonics Limited (trading as C-TEC)
Challenge Way
Martland Park
Wigan
WN5 OLD
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 - Control and Indicating Equipment
EN 54-4:1997 + A1:2002 + A2:2006 - Power Supply Equipment
EN 12094-1:2003 - Components for Gas Extinguishing Systems - Requirements and Test Methods for Electrical Automatic Control and Delay Devices

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 04 July 2022 and will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the approved product certification body.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global**UK Approved Body No. 0832**

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1111**EP203 Conventional Three Zone "Class A" Extinguisher Control Panel**

Variants:

EP203/DE Conventional three zone "class A" extinguisher control panel German Language Variant

Incorporating the following units:

SPF0000203 Main extinguisher control
SPF0000212 External relay interface
SPF0003613 Power supply unit
SPF0000214 EP214 Terminal

Incorporating modular units:

EP210S Remote Status Unit "Surface Mount" optional (See Note 1)
EP211 Economy Status Unit optional (See Note 1)

Optional language variants;

EP203/ES Spanish language variant
EP203/FR French language variant
EP203/IT Italian language variant
EP203/DE German language variant

Certified with the following options with the requirements from EN 12094-1:2003

4.17 Delay of extinguisher signal
4.18 Signal representing the flow of extinguishing agent
4.19 Monitoring of the status of components
4.20 Emergency hold device
4.21 Control of flooding time
4.23 Manual only mode
4.26 Triggering of equipment outside the system
4.27 Emergency abort device
4.30 Activation of alarm devices with different signals

Certified with the following options with requirements from EN 54-2:1997

7.8 Output to fire alarm device(s)
7.11 Delays to the auctioning of outputs fire alarm devices and fire routing equipment



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com

BRE Global

UK Approved Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-UKCA-CPR-F1111

EP203 Conventional Three Zone "Class A" Extinguisher Control Panel

7.13 Alarm counter
10 Test condition

Notes:

- 1) Optional Remote Status Unit part No. EP210S & Economy Status Unit part No. EP211 are not certified as meeting the requirements of the standards specified.
- 2) Meets the requirements of EN12094-3:2003, Class A - i.e. operational temperature range of -5°C to +40°C.



P. Halligan, Technical Manager

On behalf of BRE Global Limited

Date of First Issue: 04 July 2022

Issue Date: 04 July 2022

Issue Number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com